

Ph.: (0353) 2597240

ডাবগ্রাম ২নং গ্রাম পঞ্চায়েত করণ

Office of the Dabgram -II Gram Panchayat

আশিঘর, ডাকঘর : ঘোগোমালী, জেলা : জলপাইগুড়ি

Ashighar, Post Office : Ghogomali, Dist : Jalpaiguri

স্মারক নং...../ডাব-২নং গ্রামপা/

Memorandum No : B-244 / Dab-II G.P./



তারিখ.....

Date 25.02.22

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION

CERTIFICATE

Certified that an inspection team headed by Mrs. Lakshmi Halder, Panchayat, Dabgram – II GP from the Anchal office of the Dabgram – II Gram Panchayat inspected the premises of Jermel's Academy, Mouza Dabgram – II, Vill: - Majhabari, Siliguri on 22nd February, 2022 and found that Jermel's Academy has safe drinking water facilities for the Students and member of staff of institution and is maintaining the hygienic sanitation condition in the school building and the campus as per the norms prescribed by the Central / State / U.T. Govt.

The above is valid for a period of two years.



Signature with Seal.....

Chatterjee

PRADHAN

DABGRAM-II GRAM PANCHAYAT

Name.....

Sudha Chatterjee

Designation.....

Pradhan

To

Jermel's Academy

Mouza Dabgram – II

Majhabari East

Jungle Mahal Road

Siliguri

Dist: Jalpaiguri

Hadi
Principal
Jermel's Academy

H. Dadi
Manager
Jermel's Academy
Siliguri




GOVERNMENT OF WEST BENGAL,
DIRECTORATE OF PUBLIC HEALTH ENGINEERING,
OFFICE OF THE EXECUTIVE ENGINEER,
SILIGURI WATER SUPPLY DIVISION,
DISTRICT LABORATORY AT FULBARI,
SILIGURI


PHYSICAL AND CHEMICAL TEST REPORTS :


Date Of Collection	15.02.2022
Date Of Analysis	15.02.2022
Date Of Reporting	15.02.2022

SL. NO.	Parameters	Acceptable Limit	Cause of Rejection	RESULT	
				Place	Jermel's Academy, Ashigarh
				Source	Well (After Filtration)
				Sender	Jermel's Academy
1.	Turbidity (NTU)	1	5		0.57
2.	pH	7.0 to 8.5	<6.5 or >9.2		7.01
3.	TDS(ppm)	500	2000		267
4.	Colour(Hz)	5	25		0
5.	Iron (mg/l)	0.1	1.0		0.01
6.	Res. Chlorine (mg/l)	0.2	>1.0		0
7.	Fluoride (mg/l)	1.0	1.5		0.25
8.	Total Hardness(mg/l)	300	600		176
9.	Total Alkalinity(mg/l)	200	600		182
10.	Chloride (mg/l)	200	600		46.49
11.	Nitrate (mg/l)	45	45		4.17
12.	Copper (mg/l)	0.05	0.5		0.03

*The tests done with the Sample as deposited by the Party.
Physical & Chemical Test Charge @ Rs. 900.00/ Sample


Chemist/Bacteriologist,
District Laboratory,
Fulbari, W.T.P.


Junior Engineer,
Siliguri Water Supply Division,
P.H. Engineering Dte.



Assistant Engineer,
Siliguri Water Supply Division,
P.H. Engineering Dte.

Memo No. 2250/SWSD /SD: Dated, Siliguri, the 23/02/2022


Copy forwarded for information and necessary action to:-

1. Jermel's Academy.
2. Office Copy.

JAN-08


Executive Engineer,
Siliguri Water Supply Division,
P.H. Engineering Dte


Principal
Jermel's Academy


Manager
Jermel's Academy
Siliguri



GOVERNMENT OF WEST BENGAL,
DIRECTORATE OF PUBLIC HEALTH ENGINEERING,
OFFICE OF THE EXECUTIVE ENGINEER,
SILIGURI WATER SUPPLY DIVISION,
DISTRICT LABORATORY AT FULBARI,
SILIGURI

BACTERIOLOGICAL ANALYSIS :

Date Of Collection	15.02.2022
Time Of Collection	10.35 AM
Date Of Analysis	15.02.2022 TO 16.02.2022
Date Of Reporting	16.02.2022

Sl No.	Bacteriological Parameters	Acceptable Limit	RESULT	
			Place	Jermel's Academy , Ashigarh
			Source	Well (After Filtration)
			Sender	Jermel's Academy
1.	Total Coliform Present/Absent MPN (per 100ml)	Absent		ABSENT
2.	Faecal Coliform Present/Absent MPN (per 100ml)	Absent		ABSENT
3.	WATER BACTERIOLOGICALLY SAFE/UNSAFE	--		SAFE

*The tests done with the Sample as deposited by the Party.
Bacteriological Test Charge @ Rs. 500.00/ Sample

Chemist/Bacteriologist,
District Laboratory,
Fulbari, W.T.P.

Junior Engineer,
Siliguri Water Supply Division,
P.H. Engineering Dte.

Assistant Engineer,
Siliguri Water Supply Division,
P.H. Engineering Dte.

Memo No. 2251/SWSD /SD: Dated, Siliguri, the 23/02/2022

Copy forwarded for information and necessary action to:-

1. The Jermel's Academy.
2. Office Copy

FEB-05

Executive Engineer,
Siliguri Water Supply Division,
P.H. Engineering Dte.

Principal
Jermel's Academy

Manager
Jermel's Academy
Siliguri